



NOTE:
 A. FOR THE LOCATION OF APPURTENANCES
 SEE STANDARD DRAWING No. W-2.
 B. DISTRICT INSTALLED BACKFLOW AREA TO REMAIN CLEAR.

LEGEND ON PLANS

NO.	DESCRIPTION
1	MAIN SIZE x 1-INCH SERVICE, BRASS DOUBLE STRAP SADDLE FOR ACP & DIP, SS DOUBLE STRAP FOR PVC
2	1-INCH BRASS BALL CORPORATION STOP MIP x COMP (OPERATING NUT TO BE POSITIONED ON RIGHT SIDE)
3	1-INCH COPPER TUBING x REQUIRED LENGTH
4	BRASS BALL ANGLE METER STOP w/LOCKWING (1-INCH COMP x METER SWIVEL)
5	PLASTIC METER BOX
6	1-INCH STEEL HIGH PRESSURE 1/2 WELD THREADED COUPLING
7	WARNING TAPE
8	TRACER WIRE

APPROVED:  District Engineer	 VALLEY CENTER MUNICIPAL WATER DISTRICT STANDARD DRAWING	NOT TO SCALE
		DWG. NUMBER
03/02/2026 Date	1-INCH WATER SERVICE	W-3
3/2/2026 Latest Revision Date		